

**Merged Document Report****Application No.: PL8911**

Description :	
Address :	
Record Type :	PLAT

Submission Documents:

Document Filename
Updated Plat 9-18.pdf

Comment Author Contact Information:

Author Name	Author Email	Author Phone No.:
Mark Zans	markz2@cctexas.com	361-826-3553
Mina Trinidad	minar@cctexas.com	361-826-3259
Caleb Wong	calebw@cctexas.com	361-826-3392
Alex Harmon	alexh2@cctexas.com	361-826-1102

General Comments

Comment ID	Author : Department	Status	Review Comments	Applicant Response Comments
7	Alex Harmon : DS	Closed	Improvements Required for Recordation, per UDC 8.1.4. A. Streets: No Sidewalks: No B. Water: No Fire hydrants: No C. Wastewater: No D. Stormwater: No E. Public open space: No F. Permanent monument markers: No  Please note, improvements required should be constructed to city standards, found in Article 8 and the IDM.	

Corrections in the following table need to be applied before a permit can be issued

Comment ID	Page Reference	Annotation Type	Author : Department	Status	Review Comments	Applicant Response Comments
1	Plat1	Note	Mina Trinidad : DS	Closed	This Plat Application has requested the 30-day review tract. Please keep in mind that once the Technical Review Committee (TRC) comments are sent back to you, you will have the option to request additional review time (if needed). If you do not request additional review time, your application will be sent to Planning Commission with open comments from TRC.	
3	Plat1	Note	Alex Harmon : DS	Closed	Verify and acknowledge centerline to property line is 50 ft. This is what it should be for an A2, however, measurements on city data are 45 ft. It is recognized that city data is not always the most up to date.	
8	Plat1	Note	Mark Zans : LD	Closed	Park Fee: 1 x 462.50 = \$462.50	
5	Plat1	Note	Caleb Wong : STREET	Closed	PW STR: Informational - Please refer to City of Corpus Christi Standards and Specifications for proposing roadwork, curb and gutter, sidewalk, utilities, etc and have the standards included in the plan set and the specifications referenced. Wherever available, please include a table of contents for which standards and specifications were used.	
6	Plat1	Note	Caleb Wong : STREET	Closed	PW STR: Informational - A person shall be held responsible for damage to and in public right-of-way for the criteria outlined in Sec. 49-39-9 in the City's Municipal Code and will be held responsible for restoring the City assets per Municipal Code Sec. 49-47-1, Sec. 49-54-6 and Sec. 49-49-3. For further information, please email ROWManagement@cctexas.com.	