



## 804 14<sup>th</sup> St. – ACCESSORY STRUCTURE

- Substandard case started 2/9/2024.

Structure deemed substandard based on the following findings:

- Structure does not meet the minimum requirements and standards as set forth in the Corpus Christi Property Maintenance Code.
- Exterior of the structure is not in good repair, is not structurally sound, and does not prevent the elements or rodents from entering the structure.
- Interior of the structure is not in good repair, is not structurally sound, and is not in a sanitary condition.
- Structure is unfit for human occupancy and found to be dangerous to the life, health, and safety of the public.

City Recommendation: Demolition of accessory structure (Building Survey attached)

Property located in a residential area.

According to NCAD, the owner took possession of property 4/3/1991.

### **Case, Abatement, and Citation History**

Total number of Code complaints: 10

Total number of cases: 5

Owner Compliance: 1

City Abatements: 4

Citations issued: 0 (Owner Deceased)



**804 14<sup>th</sup> St. – ACCESSORY STRUCTURE**

Date	Case Type	Violation(s)	Status
1/5/2023	Set Out Violation	SEC. 21-22 WHEN AND WHERE SOLID WASTE IS TO BE PLACED FOR COLLECTION	COMPLIANT
11/18/2022	Zoning	Unified Development Code 1.7.2 A. Minimum Requirements	Closed
4/19/2023	Vacant Lot	Section 22-6 LITTER AND SOLID WASTE	COMPLIANT
2/8/2024	Emergency Measures	108.1.5 Dangerous Structure or Premises	VIOLATION ABATED
6/26/2024	Vacant Lot	Section 23-70 TALL WEEDS, BRUSH, AND DISEASED TREES PROHIBITED ON LOT, Section 49-10 KEEP SIDEWALKS, CURBS, AND GUTTERS CLEAN. UPON ARRIVAL OBSERVED TALL WEEDS, SIDEWALKS CURBS AND GUTTERS	IN PROGRESS

**Abatement history for 804 14<sup>TH</sup> ST**

<u>Date</u>	<u>Cost/Admin Fee</u>	<u>Case Type</u>
1. 11/16/2023	\$185.44/ \$412.00	Mowed/ Removed litter
2. 2/7/2024	\$1,680.00/\$412.00	Mowed/ Removed litter
3. 02/09/2024	\$190.00/\$174.00	Emergency Board Up
4. 10/16/2024	\$153.10/ \$412.00	Mowed/ Removed litter

Total: \$3,618.54



**804 14<sup>th</sup> St. – ACCESSORY STRUCTURE**

CCPD calls to property:

Nature of Call	804 14 <sup>th</sup> St.
Disturbance in Progress	2
Quality of Life Field Event	6
Traffic Stop	1
Disturbance weapons Involved	1
Law Enforcement Investigation Field Event	1
Suspicious or Unusual Suspicious Activity Specify	1
Residential Burglary In Proress	1
<b>Grand total</b>	<b>13</b>

Attempted contact with Property Owner(s)

DATE	NAME	CONTACT DETAILS
7/8/2024		ATTEMPTED CONTACT (361) 249-2492 STATED SHE WAS NOT THE PROPERTY OWNER OR NAME ASSOCIATED WITH PROPERTY OWNER.
2/27/23	MARIA TERESA NAVA	HEIR TO PROPERTY-DAUGHTER TO DECEASED SON ABUNDIO NAVA JR. SHE STATED SHE WAS SUPPOSEDLY THE OWNER BASED ON WHAT FAMILY HAS STATED BUT NO LEGAL PAPERWORK WAS EVER FILED. SHE STATED HER UNCLE DANIEL NAVA WAS IN A MENTAL HOSPITAL SOMEWHERE AND HER UNCLE ROGER NAVA WAS LIVING AT THE PROPERTY ABOUT SIX MONTHS AGO WITHOUT UTILITIES AND LETTING OTHER PEOPLE SQUAT THERE. I PROVIDE HER THE INFORMATION TO LINEBARGER IN CASE SHE WANTS TO INQUIRE ABOUT THE ACTIVE LAWSUIT.



**804 14<sup>th</sup> St. – ACCESSORY STRUCTURE**

2/27/23	JASON NAVA	HEIR TO PROPERTY-SON TO DECEASED HEIR ABUNDIO NAVA JR. HE STATED NO INTEREST IN PROPERTY. EXPLAINED THE BSB PROCESS FOR THE STRUCTURE AND HOW THE DEPARTMENT WILL PROCEED TO PRESENTING AT THE BSB.
6/13/2024	Theresa Villegas	She stated her brother Daniel Nava who recently died had been receiving notices for the property. I explained to her we had several cases on the property including VB, UVB, and substandard. I explained the process to her regarding the substandard procedures we follow, and that 804 14th St. was scheduled to go to the board in July. She explained no one can take care of the property or pay back taxes and understands that the state of the property can not stay in the condition.

10/28/2024

Code Compliance Supervisor: Roland Maldonado

Case# V224436-020924

Property Owner: Teresa Moreno Nava

Address (Residential Commercial): 804 14<sup>th</sup> St.

Staff Recommendation(s): **Demolition**

Residential Structure only

Accessory Structure

Commercial Structure only

Commercial and Accessory Structure

Under the provisions of Section 13-22 (H)(1)(c) of the Corpus Christi Property Maintenance Code and due to substandard and dilapidated condition of the structure(s), a hazard to the health, safety, and welfare of the public is henceforth declared.

Therefore, the owner be required to **demolish** the structure(s) within thirty (30) days. If demolition is not started and completed as required, then the City be authorized to demolish.

#### Notices

1. Letters of substandard conditions sent by certified mail.
2. Final notice sent by certified mail.
3. Certified letter of hearing sent by certified mail
4. Notice of hearing published in newspaper.

#### Additional

1. Owner Deceased:  No  Yes If deceased verification by: Obituary Death Certificate
2. Structure Entered by: Search Warrant Consent Given by: Unsecure
3. Taxes due:  Current Past due -Amount owed: \$6,674.61
4. Utilities: Active Inactive-Last active date: None
5. Year Structure Built: N/A
6. Lawsuits: Yes No
7. Code Enforcement Maintaining Property: Yes No

## COMPLAINT

Monday, October 28, 2024

Building Standards Board  
City of Corpus Christi  
2406 Leopard St.  
Corpus Christi, Texas 78408

**RE: 804 14<sup>TH</sup> ST.**

---

**Case # V224436-020924**

**OWNER: Abundio Nava Jr & WF Maria**

**Code Compliance Supervisor  
Roland Maldonado**

Dear Board Members:

Pursuant to Article II and in accordance with Section 13-22(B), of the Corpus Christi Property Maintenance Code, this Department has initiated and prepared the above listed case for your review and consideration. On **February 8, 2024**, the code official determined that there were reasonable grounds to believe there was a violation(s) of the Corpus Christi Property Maintenance Code or any rule or regulation concerning the health, safety, or general welfare adopted by the city as it relates to structures or premises and gave notice of such alleged violation to the owner of the property. Thirty days have elapsed since the notice of violation(s) was provided and such violation(s) have not been cured.

Staff recommends a hearing be set for not less than ten (10) days or more than forty-five (45) days from the date of this complaint. At this hearing staff recommendation for the above listed property will be repair/**demolition**.

If you have any questions concerning the above, please call (361) 826-3046.



Roland Maldonado  
Supervisor  
Development Services  
Code Compliance Division

cc: Carlos Martinez, Monica Pareso, Catherine Giffin, John Solberg, Merced Pena

**CASE TIMELINE FOR 804 14TH ST**

Activity	Date	Legal Requirement	Legal Reference
Code Enforcement Notified of Potential Violation	2/8/2024	n/a	n/a
Initial Inspection Completed	2/8/2024	When building, structure or premise thought to be substandard	Corpus Christi Property Maintenance Code 104.2
Notice of Violation Mailed to Last Known Addresses	2/20/2024	When there are reasonable grounds to believe there is a violation	City Ordinance Sec. 13-22(A) & (D)(2)
Notice of Violation Posted in Newspaper	5/20/2024 & 5/21/2024	When owner is unknown, whereabouts unknown, or where service of notice has failed (Published twice w/in a 10 day period)	City Ordinance Sec.13-22(A) & (D)(3)
Deadline to comply with Newspaper Notice of Violation	6/22/2024	When 30 days have elapsed from the date of first publication	City Ordinance Sec. 13-22(B)
Notice Received	2/29/2024	Returned mail rec'd-Return to sender, vacant, unable to forward	n/a
Returned Notice of Violation Posted at Front Door of Property	9/23/24-9/27/24 & 9/30/24-10/4/24	When notice is returned showing unclaimed or not delivered	City Ordinance Sec. 13-22(A) & (D)(4)
Deadline to comply with Mailed Notice of Violation	3/21/2024	30 days from receipt of the notice	City Ordinance Sec. 13-22(A)(5)
Re-inspection	3/26/2024	Not less than 30 days from receipt of the notice or when 30 days have elapsed from date of first publication	City Ordinance Sec. 13-22(B)
Complaint filed with BSB	10/28/2024	When owner refused to comply; when not cured within 30 days from receipt of notice or any further agreed time; or when 30 days have elapsed from date of first publication	City Ordinance Sec. 13-22(B)(2)
Notice of Hearing Mailed to Last Known Address	10/29/2024	At least 10 days prior to hearing	City Ordinance Sec. 13-22(C) & (D)(2)
Notice of Hearing Posted in Newspaper	10/28/2024 & 10/29/2024	At least 10 days prior to hearing when owner is unknown, whereabouts unknown, or where service of notice has failed (Published twice w/in a 10 day period)	City Ordinance Sec.13-22(C) & (D)(3)
Notice of Hearing Filed with County Clerk	10/30/2024	At least 10 days prior to hearing	City Ordinance Sec. 13-22(C) & Tx Local Gov't Code 214.001€
Returned Notice of Hearing Posted at Front Door of Property	11/11/24-11/15/24 & 11/18/24-11/20/24	When notice is returned showing unclaimed or not delivered	City Ordinance Sec. 13-22(C) & (D)(4)
BSB Agenda Posted	11/15/2024	72 hours (3 days) before scheduled time of hearing	Texas Govt. Code 551.043(a)
BSB Hearing	11/21/2024	Not less than 10 days nor more than 45 days after Complaint filed	City Ordinance Sec. 13-22 (C)

COLEMAN AVE


14TH ST

**SUBJECT  
PROPERTY**


**804 14TH ST**



*Aerial View*

 Subject Property













# CODE ENFORCEMENT DIVISION

## ACCESSORY BUILDING SURVEY



Address: 804 FOURTEENTH ST  
 Legal Description: EXT TO S END LT 5 BK 10  
 Tax Account No: 2350-0010-0050  
 Property Owner: NAVA TERESA MORENO  
 Mailing Address: 806 14TH ST  
 City, State, Zip: CORPUS CHRISTI, TX 78404

Inspection Date: 2/8/2024  
 Zoning District: CI  
 Compliance Officer: Mike Shelton  
 Placard Date: 2/8/2024  
 Case No: V224436-020924

Corrections must be made to the item(s) checked below to comply with the Corpus Christi Property Maintenance Code and/or ordinances of the City of Corpus Christi. The following city ordinances are applicable: Building, Plumbing, Electrical, Mechanical, Fire, Health and Zoning.

Permits required: Building Plumbing Electrical Mechanical Fire Other:

Accessory Structure Type: Wood Frame Masonry Fire Damage  
 (302.7, 304.1, 304.2, 304.4, 304.5, 304.6, 304.7, 305.1 & 305.2)

Roof Type: SHINGLE

- Rotten
- Loose
- Torn
- Holes
- Missing
- Other:

Wall Type: WOOD FRAME

- Rotten
- Leaning
- Buckled
- Missing
- Other:

Foundation Type: PAD

- 
- Sunken
- Cracked
- Rotten

Description	Max	Unit A	Unit B	Unit C	Unit D
Roofing Frame	16				
Roof Cover	17				
Wall Framing	18				
Siding	15				
Foundation	24				
Doors/Windows	10				
Total %	100				

## VIOLATION(S): 804 14<sup>TH</sup> ST.

108.1 General. When a structure or equipment is found by the code official to be unsafe, or when a structure is found unfit for human occupancy, or is found to be an unlawful structure, the structure or equipment shall be deemed a threat to the public health, safety or welfare.

\*\*\*

108.1.1 Unsafe structures. An unsafe structure is one that is found to be dangerous to the life, health, property or safety of the public or the occupants of the structure by not providing minimum safeguards to protect or warn occupants in the event of fire, or because such structure contains unsafe equipment or is so damaged, decayed, dilapidated, structurally unsafe or of such faulty construction or unstable foundation, that partial or complete collapse is possible.

\*\*\*

108.1.3 Structure unfit for human occupancy. A structure is unfit for human occupancy whenever the code official finds that such structure is unsafe, unlawful or, because of the degree to which the structure is in disrepair or lacks maintenance, is insanitary, vermin or rat infested, contains filth and contamination, or lacks ventilation, illumination, sanitary or heating facilities or other essential equipment required by this code, or because the location of the structure constitutes a hazard to the occupants of the structure or to the public.

\*\*\*

108.1.5 Dangerous structure or premises. For the purpose of this code, any structure or premises that has any or all of the conditions or defects described below, but which is not limited to those described below, shall be considered dangerous and may be deemed substandard:

1. Any door, aisle, passageway, stairway, exit or other means of egress that does not conform to the approved building or fire code of this City as related to the requirements for existing buildings.
2. The walking surface of any aisle, passageway, stairway, exit or other means of egress is so warped, worn loose, torn or otherwise unsafe as to not provide safe and adequate means of egress.
3. Any portion of a building, structure or appurtenance that has been damaged by fire, earthquake, wind, flood, deterioration, neglect, abandonment, vandalism or by any other cause to such an extent that it is likely to partially or completely collapse, or to become detached or dislodged, or which cannot be expected to withstand winds of hurricane force.
4. Any portion of a building, or any member, appurtenance or ornamentation on the exterior thereof that is not of sufficient strength or stability, or is not so anchored, attached or fastened in place so as to be capable of resisting natural or artificial loads of one and one-half the original designed value.
5. The building or structure, or part of the building or structure, because of dilapidation, deterioration, decay, faulty construction, the removal or movement of some portion of the ground necessary for the support, or for any other reason, is likely to partially or completely collapse, or some portion of the foundation or underpinning of the building or structure is likely to fail or give way.
6. The building or structure, or any portion thereof, is clearly unsafe for its use and occupancy.
7. The building or structure is neglected, damaged, dilapidated, unsecured or abandoned so as to become an attractive nuisance to children who might play in the building or structure to their danger, becomes a harbor for vagrants, criminals or immoral persons, or enables persons to resort to the building or structure for committing a nuisance or an unlawful act.
8. Any building or structure has been constructed, exists or is maintained in violation of any specific requirement or prohibition applicable to such building or structure provided by the approved building or fire code of the jurisdiction, or of any law or ordinance to such an extent as to present either a substantial risk of fire, building collapse or any other threat to life and safety.
9. A building or structure, used or intended to be used for dwelling purposes, because of inadequate maintenance, dilapidation, decay, damage, faulty construction or arrangement, inadequate light. Ventilation, electrical, mechanical, or plumbing system, or otherwise, is determined by the code official to be unsanitary, unfit for human habitation or in such a condition that is likely to cause sickness or disease, including all conditions conducive to the harboring of rats or mice or other disease-carrying animals or insects reasonably calculated to spread disease.
10. Any building or structure, because of a lack of sufficient or proper fire- resistance-rated construction, fire protection systems, electrical system, fuel connections, mechanical system, plumbing system or other cause, is determined by the code official to be a threat to life or health.
11. All buildings or structures which have pit privies where the same are not permitted by law or which are

not connected to the city sewer when required by law or where inadequate and unsanitary pit privies or septic tanks exist.

12. Any portion of a building remains on a site after the demolition or destruction of the building or structure or whenever any building or structure is abandoned so as to constitute such building or portion thereof as an attractive nuisance or hazard to the public.

\*\*\*

302.7 Accessory structures. All accessory structures, including detached garages, shall be maintained structurally sound and in good repair.

\*\*\*

304.1 General. The exterior of a structure shall be maintained in good repair, structurally sound and sanitary so as not to pose a threat to the public health, safety or welfare.

\*\*\*

304.13 Window, skylight and door frames. Every window, skylight, door and frame shall be kept in sound condition, good repair and weather tight.

\*\*\*

304.13.1 Glazing. Glazing materials shall be maintained free from cracks and holes.

\*\*\*

304.13.2 Openable windows. Every window, other than a fixed window, shall be easily openable and capable of being held in position by window hardware.

\*\*\*

304.15 Doors. Exterior doors, door assemblies, operator systems if provided, and hardware shall be maintained in good condition. Locks at all entrances to dwelling units and sleeping units shall tightly secure the door. Locks on means of egress doors shall be in accordance with Section 702.3.

\*\*\*

304.4 Structural members. Structural members shall be maintained free from deterioration, and shall be capable of safely supporting the imposed dead and live loads.

\*\*\*

304.4 Structural members. Structural members shall be maintained free from deterioration, and shall be capable of safely supporting the imposed dead and live loads.

\*\*\*

304.5 Foundation. All foundations, piers, or other structural elements shall be maintained plumb and capable of adequate support, free from open cracks and breaks and shall be kept in such condition so as to prevent the entry of rodents and other pests.

\*\*\*

304.6 Exterior walls. Exterior walls shall be free from holes, breaks, and loose or rotting materials; and maintained weatherproof and properly surface coated where required to prevent deterioration.

\*\*\*

304.7 Roofs and drainage. The roof and flashing shall be sound, tight and not have defects that admit rain. Roof drainage shall be adequate to prevent dampness or deterioration in the walls or interior portion of the structure. Roof drains, gutters and downspouts shall be maintained in good repair and free from obstructions. Roof water shall not be discharged in a manner that creates a public nuisance.

\*\*\*

305.1 General. The interior of a structure and equipment therein shall be maintained in good repair, structurally sound and in a sanitary condition. Occupants shall keep that part of the structure which they occupy or control in a clean and sanitary condition. Every owner of a structure containing a rooming house, housekeeping units, a hotel, a dormitory, two or more dwelling units or two or more nonresidential occupancies, shall maintain, in a clean and sanitary condition, the shared or public areas of the structure and exterior property.

\*\*\*

305.2 Structural members. Structural members shall be maintained structurally sound, and be capable of supporting the imposed loads.

\*\*\*

305.3 Interior surfaces. Interior surfaces, including windows and doors, shall be maintained in good, clean and sanitary condition. Peeling, chipping, flaking or abraded paint shall be repaired, removed or covered. Cracked or loose plaster, decayed wood and other defective surface conditions shall be corrected.

\*\*\*

305.4 Stairs and walking surfaces. Every stair, ramp, landing, balcony, porch, deck or other walking surface shall be maintained in sound condition and good repair.

\*\*\*

305.6 Interior doors. Every interior door shall fit reasonably well within its frame and shall be capable of being opened and closed by being properly and securely attached to jambs, headers or tracks as intended by the manufacturer of the attachment hardware.

\*\*\*

309.1 Infestation. All structures shall be kept free from insect and rodent infestation. All structures in which insects or rodents are found shall be promptly exterminated by approved processes that will not be injurious to human health. After pest elimination, proper precautions shall be taken to prevent reinfestation.

\*\*\*

604.3 Electrical system hazards. Where it is found that the electrical system in a structure constitutes a hazard to the occupants or the structure by reason of inadequate service, improper fusing, insufficient receptacle and lighting outlets, improper wiring or installation, deterioration or damage, or for similar reasons, to include but not limited to hazards associated with fire exposure, the code official shall require the defects to be corrected to eliminate the hazard.

\*\*\*

605.2 Receptacles. Every habitable space in a dwelling shall contain not less than two separate and remote receptacle outlets. Every laundry area shall contain not less than one grounding-type receptacle or a receptacle with a ground fault circuit interrupter. Every bathroom shall contain not less than one receptacle. Any new bathroom receptacle outlet shall have ground fault circuit interrupter protection. All receptacle outlets shall have the appropriate faceplate cover for the location.

\*\*\*

605.3 Luminaires. Every public hall, interior stairway, toilet room, kitchen, bathroom, laundry room, boiler room and furnace room shall contain not less than one electric luminaire. Pool and spa luminaires over 15 V shall have ground fault circuit interrupter protection.

\*\*\*

702.1 General. A safe, continuous and unobstructed path of travel shall be provided from any point in a building or structure to the public way. Means of egress shall comply with the International Fire Code as adopted and amended by the City.



**CASE DOCUMENTATION FOR VIOLATION LETTERS MAILED FOR BSB HEARING**  
**[ALL LETTERS ARE MAILED CERTIFIED AND FIRST CLASS]**

Case No: B1 Letters, V224436-020924

ADDRESS: 806 14<sup>TH</sup> ST.

Tax Account No: 2350-0010-0050

LAST UPDATED ON: Wednesday, November 06, 2024

Owner(s): TERESA MORENO NAVA

LETTERS MAILED from 2/21/2024-3/1/2024

MAILED TO	ASSOCIATION WITH PROPERTY	RETURNED MAIL NOTES
NAVA TERESA MORENO 806 14 <sup>TH</sup> ST. CORPUS CHRISTI, TX. 78404	DECEASED OWNER	B1 Letter Mailed on 2/21/2024 RETURNED MAIL REC'D 2/29/24- RETURN TO SENDER VACANT UNABLE TO FORWARD
TERESA MORENO NAVA 804 14 <sup>TH</sup> ST. CORPUS CHRISTI, TX. 78404	DECEASED OWNER	B1 Letter Mailed on 2/21/2024 RETURNED MAIL REC'D 2/29/24- RETURN TO SENDER VACANT UNABLE TO FORWARD
UNKNOWN HEIRS OF TERESA MORENO NAVA 806 14 <sup>TH</sup> ST. CORPUS CHRISTI, TX. 78404	UNKNOWN HEIRS OF DECEASED OWNER	B1 Letter Mailed on 2/21/2024 RETURNED MAIL REC'D 3/4/2024- RETURN TO SENDER VACANT UNABLE TO FORWARD
UNKNOWN HEIRS OF TERESA MORENO NAVA 804 14 <sup>TH</sup> ST. CORPUS CHRISTI, TX. 78404	UNKNOWN HEIRS OF DECEASED OWNER	B1 Letter Mailed on 2/21/2024 RETURNED MAIL REC'D 3/4/2024- RETURN TO SENDER VACANT UNABLE TO FORWARD
ABUNDIO NAVA III 806 14 <sup>TH</sup> ST. CORPUS CHRISTI, TX. 78404	HEIR	B1 Letter Mailed on 2/21/2024 RETURNED MAIL REC'D 3/18/24- VACANT
ABUNDIO NAVA III 804 14 <sup>TH</sup> ST. CORPUS CHRISTI, TX. 78404	HEIR	B1 Letter Mailed on 2/21/2024 RETURNED MAIL REC'D 3/4/2024- RETURN TO SENDER VACANT



		UNABLE TO FORWARD
ABUNDIO NAVA III 719 FAIRVIEW LORETTO, TN. 38469	HEIR	B1 Letter Mailed on 2/21/2024 RETURNED MAIL REC'D 3/25/24- RETURN TO SENDER ATTEMPTED NOT KNOWN UNABLE TO FORWARD
JASON NAVA 806 14 <sup>TH</sup> ST. CORPUS CHRISTI, TX. 78404	HEIR	B1 Letter Mailed on 2/21/2024 RETURNED MAIL REC'D 2/29/24- RETURN TO SENDER VACANT UNABLE TO FORWARD
JASON NAVA 804 14 <sup>TH</sup> ST. CORPUS CHRISTI, TX. 78404	HEIR	B1 Letter Mailed on 2/21/2024 RETURNED MAIL REC'D 2/29/24- RETURN TO SENDER VACANT UNABLE TO FORWARD
JASON NAVA 703 FAIRVIEW LORETTO, TN. 38469	HEIR	B1 Letter Mailed on 2/21/2024
MARIA TERESA NAVA 806 14 <sup>TH</sup> ST. CORPUS CHRISTI, TX. 78404	HEIR	B1 Letter Mailed on 2/21/2024 RETURNED MAIL REC'D 2/29/24- RETURN TO SENDER VACANT UNABLE TO FORWARD
MARIA TERESA NAVA 804 14 <sup>TH</sup> ST. CORPUS CHRISTI, TX. 78404	HEIR	B1 Letter Mailed on 2/21/2024 RETURNED MAIL REC'D 2/29/24- RETURN TO SENDER VACANT UNABLE TO FORWARD
MARIA TERESA NAVA 10000 HAMMERLY BLVD #285 HOUSTON, TX. 77080	HEIR	B1 Letter Mailed on 2/21/2024
DANIEL NAVA 806 14 <sup>TH</sup> ST. CORPUS CHRISTI, TX. 78404	HEIR	B1 Letter Mailed on 2/21/2024 RETURNED MAIL REC'D 4/11/24- RETURN TO SENDER UNCLAIMED UNABLE TO FORWARD
DANIEL NAVA 804 14 <sup>TH</sup> ST. CORPUS CHRISTI, TX. 78404	HEIR	B1 Letter Mailed on 2/21/2024 RETURNED MAIL REC'D 3/22/24- NO SUCH NUMBER
ROGER NAVA	DECEASED HEIR	B1 Letter Mailed on 2/21/2024

806 14 <sup>TH</sup> ST. CORPUS CHRISTI, TX. 78404		RETURNED MAIL REC'D 4/11/24- RETURN TO SENDER UNCLAIMED UNABLE TO FORWARD
ROGER NAVA 804 14 <sup>TH</sup> ST. CORPUS CHRISTI, TX. 78404	DECEASED HEIR	B1 Letter Mailed on 2/21/2024 RETURNED MAIL REC'D 3/5/2024- RETURN TO SENDER VACANT UNABLE TO FORWARD
FEDERAL HOME LOAN MORTGAGE CORP-A FINANCIAL INSTITUTION-LIENHOLDER 8200 JONES DR. MCLEAN, VA. 22102-3110	LIENHOLDER	B1 Letter Mailed on 2/21/2024 RETURNED GREEN CARD REC'D 3/4/24- SIGNED AND REC'D BY JAMELL NEWMARK DATE OF DELIVERY 2/26/24
FEDERAL HOME LOAN MORTGAGE CORP-A FINANCIAL INSTITUTION-LIENHOLDER 806 14 <sup>TH</sup> ST. CORPUS CHRISTI, TX. 78404	LIENHOLDER	B1 Letter Mailed on 2/21/2024 RETURNED MAIL REC'D 4/11/24- RETURN TO SENDER UNCLAIMED UNABLE TO FORWARD
FEDERAL HOME LOAN MORTGAGE CORP-A FINANCIAL INSTITUTION-LIENHOLDER 804 14 <sup>TH</sup> ST. CORPUS CHRISTI, TX. 78404	LIENHOLDER	B1 Letter Mailed on 2/21/2024 RETURNED MAIL REC'D 3/22/24- UNCLAIMED
ALAMDOR S. HAMDANI-US ATTN, SOUTH DISTRICT OF TEXAS-LIENHOLDER 1000 LOUISIANA SUITE 2300 HOUSTON, TX. 77002	LIENHOLDER	B1 Letter Mailed on 2/21/2024 RETURNED GREEN CARD REC'D 3/4/24- SIGNED AND REC'D BY UNREADABLE DATE OF DELIVERY 2/26/24
ALAMDOR S. HAMDANI-US ATTN, SOUTH DISTRICT OF TEXAS-LIENHOLDER 806 14 <sup>TH</sup> ST. CORPUS CHRISTI, TX. 78404	LIENHOLDER	B1 Letter Mailed on 2/21/2024 RETURNED MAIL REC'D 4/11/24- RETURN TO SENDER UNCLAIMED UNABLE TO FORWARD
ALAMDOR S. HAMDANI-US ATTN, SOUTH DISTRICT OF TEXAS-LIENHOLDER 804 14 <sup>TH</sup> ST. CORPUS CHRISTI, TX. 78404	LIENHOLDER	B1 Letter Mailed on 2/21/2024 RETURNED MAIL REC'D 3/8/24- RETURN TO SENDER NO SUCH NUMBER UNABLE TO FORWARD
HUDSON & KEYSE LLC-LIENHOLDER 382 BLACKBROOK DR. PAINESVILLE, OH. 44077-1294	LIENHOLDER	B1 Letter Mailed on 2/21/2024 RETURNED MAIL REC'D 3/29/24- RETURN TO SENDER ATTEMPTED NOT KNOWN UNABLE TO FORWARD

HUDSON & KEYSE LLC-LIENHOLDER 806 14 <sup>TH</sup> ST. CORPUS CHRISTI, TX. 78404	LIENHOLDER	B1 Letter Mailed on 2/21/2024 RETURNED MAIL REC'D 4/11/24- RETURN TO SENDER UNCLAIMED UNABLE TO FORWARD
HUDSON & KEYSE LLC-LIENHOLDER 804 14 <sup>TH</sup> ST. CORPUS CHRISTI, TX. 78404	LIENHOLDER	B1 Letter Mailed on 2/21/2024 RETURNED MAIL REC'D 3/5/2024- RETURN TO SENDER VACANT UNABLE TO FORWARD
TEXAS SEC OF STATE FOR HUDSON & KEYSE LLC- LIENHOLDER 1019 BRAZOS ST. JAMES S. EARL RUDDER BUILDING PO BOX 12079 AUSTIN, TX. 78711-2079	LIENHOLDER	B1 Letter Mailed on 2/21/2024 RETURNED GREEN CARD REC'D 2/26/24- SIGNED BY TEXAS COMPTROLLER STAMP DATE OF DELIVERY 2/23/24
TEXAS SEC OF STATE FOR HUDSON & KEYSE LLC- LIENHOLDER 806 14 <sup>TH</sup> ST. CORPUS CHRISTI, TX. 78404	LIENHOLDER	B1 Letter Mailed on 2/21/2024 RETURNED MAIL REC'D 4/11/24- RETURN TO SENDER UNCLAIMED UNABLE TO FORWARD
TEXAS SEC OF STATE FOR HUDSON & KEYSE LLC- LIENHOLDER 806 14 <sup>TH</sup> ST. CORPUS CHRISTI, TX. 78404	LIENHOLDER	B1 Letter Mailed on 2/21/2024 RETURNED MAIL REC'D 3/5/2024- RETURN TO SENDER VACANT UNABLE TO FORWARD
THERESA NAVA VILLEGAS 806 14 <sup>TH</sup> ST. CORPUS CHRISTI, TX. 78404	HEIR	B1 Letter Mailed on 3/1/2024 RETURNED MAIL REC'D 3/15/24- RETURN TO SENDER VACANT UNABLE TO FORWARD
THERESA NAVA VILLEGAS 804 14 <sup>TH</sup> ST. CORPUS CHRISTI, TX. 78404	HEIR	B1 Letter Mailed on 3/1/2024 RETURNED MAIL REC'D 3/15/24- RETURN TO SENDER VACANT UNABLE TO FORWARD
THERESA NAVA VILLEGAS 4829 MILDRED CORPUS CHRISTI, TX. 78411	HEIR	B1 Letter Mailed on 3/1/2024 RETURNED MAIL REC'D 3/15/24- RETURN TO SENDER UNDELIVERABLE AS ADDRESSED UNABLE TO FORWARD

UNKNOWN HEIRS OF ROGER NAVA 806 14 <sup>TH</sup> ST. CORPUS CHRISTI, TX. 78404	UNKNOWN HEIRS OF DECEASED HEIR	B1 Letter Mailed on 3/1/2024 RETURNED MAIL REC'D 3/15/24- RETURN TO SENDER VACANT UNABLE TO FORWARD
UNKNOWN HEIRS OF ROGER NAVA 804 14 <sup>TH</sup> ST. CORPUS CHRISTI, TX. 78404	UNKNOWN HEIRS OF DECEASED HEIR	B1 Letter Mailed on 3/1/2024 RETURNED MAIL REC'D 3/15/24- RETURN TO SENDER VACANT UNABLE TO FORWARD