

BOILER #3 – PRO TECH CONTRACT



AIRPORT BOARD MEETING

AUGUST 30TH, 2023

Boiler Replacement

- Six-month contract with Protech Mechanical through Buyboard Cooperative for amount not to exceed \$91,627 for replacement of boiler and bladder tank.
- When terminal building was expanded and renovated in 2001, boilers were 15 years old and in good condition to be relocated. Typical useful life of boilers is 20-25 years.
- Year 1 of 3 of Asset Management Program to replace boilers.