



**Merged Document Report**

**Application No.: PL8620**

Description :	
Address :	
Record Type :	PLAT

Submission Documents:

Document Filename
240422-PLAT.R1.pdf
240422-Utility.R1.pdf

Comment Author Contact Information:

Author Name	Author Email	Author Phone No.:
Mark Zans	markz2@cctexas.com	361-826-3553
Bria Whitmire	briaw@cctexas.com	361-826-3268
Mikail Williams	MikailW@cctexas.com	
Caleb Wong	calebw@cctexas.com	361-826-3392

[General Comments](#)

[Corrections in the following table need to be applied before a permit can be issued](#)

Comment ID	Page Reference	Annotation Type	Author : Department	Status	Review Comments	Applicant Response Comments
8	P001	Note	Bria Whitmire : DS	Closed	Improvements Required for Recordation, per UDC 8.1.4: A. Streets: no Sidewalks: no B. Water: no Fire hydrants: yes, upon development C. Wastewater: no (septic) D. Stormwater: no E. Public open space: no F. Permanent monument markers: no Please note, improvements required should be constructed to city standards, found in Article 8 and the IDM.	
10	P001	Note	Bria Whitmire : DS	Closed	Remove note 8 as property has now been annexed. (Will need to submit tap application form and meter sizing form upon development.)	
11	P001	Note	Bria Whitmire : DS	Closed	Update year shown on Nueces County Health stamp from 2022 to 2025.	
2	P001	Note	Mark Zans : LD	Closed	Plat is a final plat. PC approval will be needed.	
3	P001	Note	Mark Zans : LD	Closed	This plat is on the 30-day tract for approval, approval with Conditions, or disapproval by 5/28/25 The deadline for revisions to be submitted is 5/19/25.	
4	P001	Note	Mark Zans : LD	Closed	The plat will be recommended as Conditional Approval for Resolution comments received and that have remained Open and unmet.	
5	P001	Note	Mark Zans : LD	Closed	A request or response may be made for an additional 30 days for Public Notice plat with a Waiver or to resolve Open comments. This request must be made directly to Development Services within the 30-day initial period.	
7	P001	Callout	Mark Zans : LD	Closed	Change Al Raymond name to Michael Dice.	
15	P001	Note	Mark Zans : LD	Closed	Fire comments 1-10  1PlatNote: All code reference is based on currently adopted International Fire Code (IFC) 2021 and Corpus Christi Water Distribution Standards. 2Plat"Commercial Development shall have a fire flow of 1,500 GPM with 20 psi residual Fire hydrant every 300 feet and operational." 3Plat507.5.1 (amendment) Where Required: All premises, other than one-family detached dwellings, where buildings or portions of buildings are located more than 150 feet from a fire hydrant shall be provided with approved on-site hydrants	

Comment ID	Page Reference	Annotation Type	Author : Department	Status	Review Comments	Applicant Response Comments
					<p>and water mains capable of supplying the fire flow require by the fire official. The minimum arrangement being so as to have a hydrant available for distribution of hose to any portion of building on the premises at distances not exceeding 300 feet.</p> <p>4 Infor. 507.5.4 Obstruction. Unobstructed access to fire hydrants shall be maintained at all times. The fire department shall not be deterred or hindered from gaining immediate access to fire protection equipment or fire hydrants. Note: Hose lay from a hydrant will not cross an arterial street.</p> <p>5 Infor. 912.2.3 (amendment) Proximity to Hydrant: Fire department connections (FDC) for each sprinkler system or standpipe system shall be located not more than 100 feet from the nearest fire hydrant connected to an approved water source</p> <p>6 Infor. 503.1.1 (amendment) Buildings and facilities: Approved fire apparatus access roads shall be provided for every facility, building, or portion of a building hereafter constructed or moved into or within the jurisdiction. The fire apparatus access road shall allow access to three (3) sides of buildings in excess of fifteen thousand (15,000) square feet and all sides for buildings in excess of thirty thousand (30,000) square feet.</p> <p>7 Infor. 3310.1 Required access. Approved vehicle access for firefighting shall be provided to all construction or demolition sites. Vehicle access shall be provided to within 100 feet of temporary or permanent fire department connections. Vehicle access shall be provided by either temporary or permanent roads, capable of supporting vehicle loading under all weather conditions. Vehicle access shall be maintained until permanent fire apparatus access roads are available.</p> <p>8 Infor. D102.1 Access and loading. Facilities, buildings, or portions of buildings hereafter constructed shall be accessible to fire department apparatus by way of an approved fire apparatus access road with an asphalt, concrete or other approved driving surface capable of supporting the imposed load of fire apparatus weighing at least 75,000 pounds.</p> <p>9 Infor. 503.1.1 (amendment) Buildings and facilities: During construction, when combustibles are brought on to the site in such quantities as deemed hazardous by the fire official, access roads</p>	

Comment ID	Page Reference	Annotation Type	Author : Department	Status	Review Comments	Applicant Response Comments
					<p>and a suitable temporary supply of water acceptable the fire department shall be provided and maintained.</p> <p>10 Infor. Note: An accessible road and a suitable water supply is required once construction materials are brought on site.</p>	
16	P001	Note	Mark Zans : LD	Closed	<p>Fire comments 11-20</p> <p>11 Infor. 503.2.1 Dimensions. Fire apparatus access roads shall have an unobstructed width of not less than 20 feet, exclusive of shoulders and an unobstructed vertical clearance of not less than 13 feet 6 inches.</p> <p>12 Infor. D103.1 Access road width with a hydrant. Where a fire hydrant is located on a fire apparatus access road, the minimum road width shall be 26 feet, exclusive of shoulders.</p> <p>13 Infor. "The minimum required width of 20 feet that shall be maintained means a clear unobstructed path that allows the passage of fire apparatus.</p> <p>1. Where Fire Apparatus Access is constructed to the minimum of 20 feet, no parking is allowed within the fire apparatus lane.</p> <p>2. Where a fire hydrant is located on the street, the minimum unobstructed clearance shall be 26 feet. In this instance, no parking is allowed on one side of the street.</p> <p>3. The minimum UDC residential street width is 28 ft. curb to curb. Any parking along the street that reduces the width to less than 20 ft. is prohibited and the Fire Code Official and will require painting "NO PARKING-FIRE LANE" along one side of the street."</p> <p>14 Infor. Note: Calculated Turning Radii for Fire Apparatus:  Inside Turn: 20 ft. 3 in.  Curb to curb: 36 ft. 8 in.  Wall to wall: 44 ft. 8 in.  Note: The turning radius for fire apparatus should not be less than 45 degrees and curb to curb 36 feet. As a result, developers should be particularly careful not to design streets with acute angles that would prevent fire apparatus from completing a turn without having to back up to negotiate the turn."</p> <p>15 Infor. D105.1 Where required. Where the vertical distance between the grade plane and the</p>	

Comment ID	Page Reference	Annotation Type	Author : Department	Status	Review Comments	Applicant Response Comments
					<p>highest roof surface exceeds 30 feet, approved aerial fire apparatus access roads shall be provided. For purposes of this section, the highest roof surface shall be determined by measurement to the eave of a pitched roof, the intersection of the roof to the exterior wall, or the top of parapet walls, whichever is greater</p> <p>16 Infor. D105.2 Width. Aerial fire apparatus access roads shall have a minimum unobstructed width of 26 feet, exclusive of shoulders, in the immediate vicinity of the building or portion thereof.</p> <p>17 Infor. D105.3 Proximity to building. At least one of the required access routes meeting this condition shall be located within a minimum of 15 feet and a maximum of 30 feet from the building and shall be positioned parallel to one entire side of the building. The side of the building on which the aerial fire apparatus access road is positioned shall be approved by the fire code official.</p> <p>18 Infor. D105.4 Obstructions. Overhead utility and power lines shall not be located over the aerial fire apparatus access road or between the aerial fire apparatus road and the building. Other obstructions shall be permitted to be placed with the approval of the fire code official.</p> <p>19 Infor. 503.4 Obstruction of fire apparatus access roads. Fire apparatus access roads shall not be obstructed in any manner, including the parking of vehicles. The minimum widths and clearances established in sections D103 shall always be maintained.</p> <p>20 Infor. 503.3 Marking: Where required by the fire code official, approved signs, or other approved notices the include the words NO PARKING-FIRE LANE shall be provided for fire apparatus access roads to identify such roads to prohibit the obstruction thereof. The designation of a fire lane can be marked with conspicuous signs which have the words: "Fire Lane-No Parking" at 50-foot intervals. In lieu of signs, fire lanes may be marked along curbing with the wording, "Fire Lane-No Parking" at 15-foot intervals.</p>	
17	P001	Note	Mark Zans : LD	Closed	<p>Fire comments 21-24</p> <p>21 Infor. Table D103.4 Requirements for Dead-end fire apparatus access roads. Turnaround provisions shall be provided with a 96-foot diameter cul-de-sac.</p> <p>22 Infor. 503.2.5 Dead ends. Dead-end fire apparatus access roads more than 150 feet in length shall be provided with an approved area for</p>	

Comment ID	Page Reference	Annotation Type	Author : Department	Status	Review Comments	Applicant Response Comments
					<p>turning around fire apparatus.</p> <p>23 Infor. D103.5 Fire apparatus access road gates. If installed-Gates securing the fire apparatus access roads shall comply with all the following criteria: Single gate width shall not be less than 20 feet. 12 feet gate width is required for a divided roadway. Electric gates shall be equipped with a means of opening the gate by fire department personnel for emergency access. Emergency opening devices shall be approved by the fire code official. Note: The use of a Knox Gate Switch is currently required by the Fire Official. Methods of locking shall be submitted for approval by the fire code official. Note: The Knox Padlock is currently required by the Fire Official. Electric gate operators, where provided, shall be listed in accordance with UL 325. Gates intended for automatic operation shall be designed, constructed, and installed to comply with the requirements of ASTM F 2200.</p> <p>24 Plat Commercial development of the property will require further Development Services review.</p>	
13	P001	Note	Caleb Wong : STREET	Closed	PW STR: Informational: Based on the Corpus Christi GIS Viewer, This section of Weber Rd is TxDOT jurisdiction. Please coordinate with TxDOT.	
14	P001	Note	Caleb Wong : STREET	Closed	PW STR: Informational: Based on the Corpus Christi GIS Viewer, County Rd 47 is Nueces County jurisdiction. Please coordinate with Nueces County.	
12	P002	Note	Mikail Williams : WTR	Closed	Water construction is not required for platting (UDC 1.2.1.D & 8.2.6; Water Distribution Standards).	