TECHNICAL REVIEW COMMITTEE (TRC) PLAT REVIEW COMMENTS

Interdepartmental Staff and outside agencies have reviewed and prepared comments for the proposed plat. These comments are intended to be final.

All plats must comply with applicable review criteria. All corrected plats must be submitted with a comment resolution (response) letter for staff review.

The application will be considered void after 180 days if no comments are submitted responding to distributed TRC comments.

Staff Only/District#: NV District-4

App Received: Received 04/23/21, Processed on 05/19/21 Deadline

TRC Meeting Date: 05/27/21

TRC Comments Sent Date: 05/28/21

Revisions Received Date (R1): 8-16-21 5:51pm

Staff Response Date (R1): 8-18-21
Revisions Received Date (R2): N/A
Staff Response Date (R2): N/A

Planning Commission Date: 9-15-21 Public Notice Plat

Major plats, in compliance with review criteria, are recommended for approval to the Planning Commission by the TRC. Development Services staff will determine when the plat is scheduled for Planning Commission.

Administrative plats, in compliance with review criteria, are approved by the Director on a rolling basis.

Project: 21PL1067

FLOUR BLUFF ESTATES NO.2 BLOCK 8 LOTS 14A & 14B (FINAL REPLAT- 0.379 ACRES)

Located south of Webb street and west of Jane Street.

Zoned: RS-6

Owner: GTMM LLC

Surveyor: HAYDEN SURVEYING, INC.

The applicant proposes to plat the property to subdivide one lot into two lots.

GIS									
No.	Sheet	Comment	Applicant Response	Staff Resolution	Applicant Response	Staff Resolution			
		Plat closes to acceptable							
		engineering standards. (TSPS							
		Manual of Practice Appendix A,							
		Condition 3; Suburban Traverse							
1	Plat	Error of Closure)	Informational comment.						
		Metes and bounds call missing							
		on eastern boundary. Pls	Missing metes and bound						
2	Plat	revise.	call added to plat.	Resolved.					
		Plat title should reflect lots							
		being platted (14A, 14B). Pls	Plat title corrected to						
3	Plat	revise	name lots 14A & 14B.	Resolved.					

LAND DEVELOPMENT

No.	Sheet	Comment	Applicant Response	Staff Resolution	Applicant Response	Staff Resolution
		Remove note 9. zoning note.				
		(this note relates to preliminary				
1	Plat	plats only.)	Note 9 removed from plat.	Addressed		
		Remove "Vol 8 page 22				
		M.R.N.C.T." from proposed	"vol. 8 Pg. 22" reference			
2	Plat	plat.	removed from plat.	Addressed		
		Replace "25' B.L" to read as				
3	Plat	"25' Y.R."	25' B.L. changed to 25' Y.R.	Addressed		
		Mention acreage for proposed	Acreage information			
4	Plat	subdivided lots.	added to plat.	Addressed		
		Water distribution lot fee - 2				
5	Plat	lots x \$182.00 = \$365.00	Informational comment.	Prior to plat recordation		
		Wastewater distribution lot fee				
6	Plat	- 2 lots x \$393.00 = \$786.00	Informational comment.	Prior to plat recordation		

PLAN	PLANNING/Environment & Strategic Initiatives (ESI)									
No.	Sheet	Comment	Applicant Response	Staff Resolution	Applicant Response	Staff Resolution				
1	Plat	No comment.								

DEVELOPMENT SERVICES ENGINEERING				
Action	Yes	No		
Public Improvements Required?		No		
Water		No		
Fire Hydrants		No		
Wastewater		No		
Manhole		No		
Stormwater		No		
		No, Developed area with		
Sidewalks		existing sidewalks		
Streets		No		

Refer to UDC Section 3.8.3.D Waivers if applicable.

Applicant Response on Waiver:	

DEVELOPMEN	DEVELOPMENT SERVICES ENGINEERING								
No. Sheet	Comment	Applicant Response	Staff Resolution	Applicant Response	Staff Resolution				

	Development on this site shall manage storm water drainage caused by the development of the property, drainage directed			
	to the property by ultimate development, and drainage			
	naturally flowing onto and through the property per UDC	To be addressed during		
1 Plat	8.2.8.B.2 There are two utility lines	building permitting.	Addressed	
	shown in the Web Drive R-o-W. With one label, "8" Clay			
	Wastewater Line" identify and	Second line is a duplicate.		
2 Utility	label the second utility.	Removed from Utility Plan	n. Addressed	

UTIL	UTILITIES ENGINEERING								
No.	Sheet	Comment	Applicant Response	Staff Resolution	Applicant Response	Staff Resolution			
		No water construction is							
1	Plat	required for platting.	Informational comment.						
		No wastewater construction is							
2	Plat	required for platting.	Informational comment.						

SOLI	SOLID WASTE									
No.	Sheet	Comment	Applicant Response	Staff Resolution	Applicant Response	Staff Resolution				
1	Plat	No comment.								

TRA	TRAFFIC ENGINEERING									
No.	Sheet	Comment	Applicant Response	Staff Resolution	Applicant Response	Staff Resolution				
		Proposed driveway access to a								
		public City Street shall conform								
		to access management								
		standards outlined in Article 7	To be addressed during							
1	Plat	of the UDC (UDC 7.1.7)	building permitting.							

FLOC	FLOODPLAIN									
No.	Sheet	Comment	Applicant Response	Staff Resolution	Applicant Response	Staff Resolution				
1	Plat	No comment.								

FIRE	IRE DEPARTMENT - INFORMATIONAL, REQUIRED PRIOR TO BUILDING PERMIT									
No.	Sheet	Comment	Applicant Response	Staff Resolution	Applicant Response	Staff Resolution				
1	Plat	Fire has no comment.								

GAS						
No.	Sheet	Comment	Applicant Response	Staff Resolution	Applicant Response	Staff Resolution
1	Plat	No comment.				

PAR	PARKS						
No.	Sheet	Comment	Applicant Response	Staff Resolution	Applicant Response	Staff Resolution	
1	Plat	No comment.					

COR	CORPUS CHRISTI REGIONAL TRANSPORTATION AUTHORITY							
No.	Sheet	Comment	Applicant Response	Staff Resolution	Applicant Response	Staff Resolution		
		This final replat is not located						
		along an existing or foreseeably						
1	Plat	planned CCRTA service route.	Informational comment.					

COR	CORPUS CHRISTI INTERNATIONAL AIRPORT							
No.	Sheet	Comment	Applicant Response	Staff Resolution	Applicant Response	Staff Resolution		
		1.09 miles southwest of Truax						
		airfield. May require						
		aeronautical study based on						
		type and method of	Single-Family residential					
1	Plat	construction.	use proposed					

NAS	IAS CORPUS CHRISTI						
No.	Sheet	Comment	Applicant Response	Staff Resolution	Applicant Response	Staff Resolution	
		Located in APZ-2 for NASCC.					
		Recommended 1-2 dwellings					
		per unit. Will be subjected to	Single-Family residential				
1	Plat	aircraft overflight and noise.	use proposed.				

AEP-TRANSMISSION						
No.	Sheet	Comment	Applicant Response	Staff Resolution	Applicant Response	Staff Resolution
1	Plat	No comment.				

AEP-DISTRIBUTION						
No.	Sheet	Comment	Applicant Response	Staff Resolution	Applicant Response	Staff Resolution
1	Plat	No comment.				

TXDOT						
No.	Sheet	Comment	Applicant Response	Staff Resolution	Applicant Response	Staff Resolution
1	Plat	No comment.				

NUE	NUECES ELECTRIC						
No.	Sheet	Comment	Applicant Response	Staff Resolution	Applicant Response	Staff Resolution	
1	Plat	No comment.					

INFORMATIONAL

Comments noted below apply to the preliminary site/utility/transportation plan and preliminary storm water quality management plan (SWQMP) as observations for information only.

These comments should be considered during subsequent site and public infrastructure development but may be required as a condition for plat consideration by the Planning Commission for approval.

1.	L. Prior to recordation, provide a tax certificate indicating that all taxes have a \$0.00 balance, along with the submittal of the original tracing.							

Additional comments may be issued with the subsequent submittal plans associated with the property development.

LAND DEVELOPMENT