



Legislation Details (With Text)

File #:	21-1561	Version:	1	Name:	
Type:	Ordinance	Status:		Passed	
File created:	10/29/2021	In control:		City Council	
On agenda:	11/16/2021	Final action:		12/7/2021	
Title:	Ordinance amending Chapter 55 of the Corpus Christi Code to require industrial facilities to have either a reduced pressure backflow device or air gap at each City meter servicing potable water; a double check assembly for fire service lines; an industrial district affidavit upon installing, repairing, or replacing a reduced pressure backflow preventer or an air gap; annual backflow preventer testing; and providing for penalty.				
Sponsors:	Utilities Department				
Indexes:					
Code sections:					
Attachments:	1. 21-1561 Agenda Memo Sections 55-96 and 55-37.pdf, 2. Ordinance - Industrial Backflow Update ALA 11.11.21.pdf				

Date	Ver.	Action By	Action	Result
12/7/2021	1	City Council	passed on second reading as amended	Pass
11/16/2021	1	City Council	passed on first reading	Pass
11/9/2021	1	City Council	tabled	Pass

Ordinance amending Chapter 55 of the Corpus Christi Code to require industrial facilities to have either a reduced pressure backflow device or air gap at each City meter servicing potable water; a double check assembly for fire service lines; an industrial district affidavit upon installing, repairing, or replacing a reduced pressure backflow preventer or an air gap; annual backflow preventer testing; and providing for penalty.